

Mr. Ed Gastle  
Marketing Manager  
JDSU Inc

16 Nov. 2011

**Subject: JDSU Certifier40G Approval**

Dear Ed,

Effective immediately, SETEC is pleased to announce the approval of the Certifier40G NGC4500-FA. This approval is based upon evaluation of the Certifier40G versus a variety of links and channels and with laboratory network analyzer references at SETEC Labs.

Certifier40G is approved for use in both Permanent Link and Channel certification testing with all SETEC Category 6A/Class EA, Category 6/Class E and Category 5e/Class D system warranties.

The following configuration of Certifier40G is required.

NGC4500-FA software version 3.9 or higher  
Certifier40GReporter software version 3.9 or higher

Channel testing for Category 6 A/Class EA, Category 6/Class E and Category 5e/Class D	NGC-4500-6ACH2 - pair of CAT 6A Channel adapters
Permanent Link testing for Category 6A/Class EA, Category 6/Class E and Category 5e/Class D	NGC-4500-6ALKIT2 – pair of CAT 6 A permanent link kits: each consisting of a CAT 6 A permanent link adapter NGC-AD-6ALINK and a Permanent Link test cord NGC-AC-6ALCORD

Best Regards

Franz Neff

